

SCE Compliance Monthly Report February 2010

Date of Report Generation: 3/1/2010

QSE	Avg SCE (1min) All	SCE PERFORMANCE CRITERIA			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score %	Unadj. Score %	Adj. Score %
Non-Wind QSEs					
MPOWER2 LLC (QSE)	1.1	201.2	201.2	99.9	99.9
TRQ4 (SQ4)	0.1	199.1	199.1	99.8	99.8
TRQ9 (SQ9)	1.0	206.1	206.1	99.5	99.5
FORMOSA UTILITY VENTURE LTD (QSE)	1.8	199.9	199.9	99.5	99.5
MORGAN STANLEY CAPITAL GROUP INC MSCG1 (SQ1)	3.0	200.4	200.4	99.4	99.4
MORGAN STANLEY CAPITAL GROUP INC MSCG1 TPZLAR (SQ2)	2.3	200.1	200.1	99.3	99.3
LOWER COLORADO RIVER AUTHORITY (QSE)	6.8	195.5	195.5	99.3	99.3
SHELL ENERGY NORTH AMERICA (US) LP (SQ2)	1.7	158.4	158.4	99.2	99.2
SOUTH TEXAS ELECTRIC CO OP INC (QSE)	2.0	166.7	166.7	98.9	98.9
BPTX (SQ1)	2.8	201.8	201.8	98.9	98.9
CONSTELLATION ENERGY COMMODITIES GROUP INC C (QSE)	33.7	195.2	195.2	98.6	98.6
TRQ7 (SQ7)	2.0	200.1	200.1	98.5	98.5
TENASKA POWER SERVICES CO (QSE)	3.9	189.8	189.8	98.4	98.4
RIO NOGALES POWER PROJECT LP (QSE)	4.1	204.7	204.7	98.2	98.2
CITY OF GARLAND (SQ2)	1.2	196.7	196.7	98.2	98.2
ANP FUNDING I LLC (QSE)	4.6	204.4	204.4	98.0	98.0
PSEG ENERGY RESOURCES AND TRADE LLC (ODESSA) (SQ2)	4.8	162.2	162.2	97.8	97.8
OCCIDENTAL POWER SERVICES INC (QSE)	3.5	194.8	194.8	97.7	97.7
DIRECT ENERGY LP (QSE)	4.3	204.3	204.3	97.4	97.4
RELIANT ENERGY POWER SUPPLY LLC (QSE)	3.6	203.7	203.7	97.0	97.0
SHELL ENERGY NORTH AMERICA (US) LP (QSE)	5.0	174.3	174.3	96.9	96.9
BRAZOS ELECTRIC POWER CO OP INC (QSE)	6.3	183.0	183.0	96.6	96.6
OPTIM ENERGY MARKETING LLC (SQ1)	6.5	146.1	146.1	96.3	96.3
PSEG ENERGY RESOURCES AND TRADE LLC (GUADALUPE) (SQ1)	8.0	144.9	144.9	96.3	96.3
LUMINANT ENERGY COMPANY LLC (SQ3)	6.4	197.4	197.4	96.2	96.2
NEXTERA ENERGY POWER MARKETING LLC (QSE)	14.3	184.0	184.0	95.6	95.6
IPA TRADING LLC (SQ1)	12.1	159.2	159.2	95.4	95.4
CITY OF AUSTIN DBA AUSTIN ENERGY (QSE)	10.3	178.1	178.1	95.3	95.3
EXELON GENERATION COMPANY LLC (QSE)	6.2	157.7	157.7	95.1	95.1
EAGLE INDUSTRIAL (SQ3)	3.4	212.6	212.6	94.7	94.7
GDF SUEZ ENERGY MARKETING NA INC (QSE)	7.6	171.2	171.2	94.6	94.6
CPS ENERGY (QSE)	16.3	170.1	170.1	94.5	94.5
CONSTELLATION ENERGY COMMODITIES GROUP INC (QSE)	7.0	207.0	207.0	94.4	94.4
CITY OF GARLAND (QSE)	4.5	169.4	169.4	94.2	94.2
LUMINANT ENERGY COMPANY LLC (QSE)	19.9	174.4	174.4	94.2	94.2
OPTIM ENERGY MARKETING LLC (QSE)	9.2	169.5	169.5	93.8	93.8
EAGLE INDUSTRIAL (SQ4)	7.4	173.6	173.6	93.7	93.7
AMERICAN ELECTRIC POWER SERVICE CORP	5.4	163.6	163.6	93.0	93.0
CALPINE POWER MANAGEMENT LP	24.5	161.6	161.6	87.4	92.1
NRG TEXAS POWER LLC (QSE)	12.3	169.9	169.9	91.8	91.8
TRQ1 (SQ1)	8.3	211.6	211.6	91.5	91.5
BTU QSE SERVICES INC	4.5	189.3	189.3	91.3	91.3
EAGLE ENERGY PARTNERS I LP (QSE)	8.3	175.9	175.9	90.6	90.6
Wind Only					
SOUTH TEXAS ELECTRIC COOPERATIVE INC WIND (SQ2)	6.4	204.5	204.5	85.0	85.0
EC AND R PAPALOTE (SQ6)	9.2	201.4	201.4	81.7	81.7
FULCRUM POWER SERVICES LP (SQ2)	8.2	195.8	195.8	76.1	76.1
SILVER STAR I POWER PARTNERS LLC (QSE)	8.3	200.1	200.1	75.3	75.3
SWEETWATER WIND 5 LLC (QSE)	10.3	211.7	211.7	69.3	69.3
BULL CREEK WIND LLC (QSE)	17.3	195.2	195.2	62.8	62.8
INVENERGY CAMP SPRINGS II (SQ2)	14.2	203.1	203.1	58.5	58.5

QSE	Avg SCE (1min) All	SCE PERFORMANCE CRITERIA			
		SCPS1		SCPS2	
		Unadj. Score %	Adj. Score %	Unadj. Score %	Adj. Score %
Wind Only					
INVENERGY CAMP SPRINGS (SQ1)	14.7	204.6	204.6	57.9	57.9
INVENERGY STANTON (SQ3)	14.5	203.7	203.7	57.1	57.1
MORGAN STANLEY CAPITAL GROUP INC MSCG LORAIN WIND (SQ3)	19.9	201.6	201.6	54.4	54.4
EC AND R CHAMPION (SQ1)	17.6	198.8	198.8	51.7	51.7
INVENERGY MCADOO (SQ4)	20.4	205.8	205.8	50.9	50.9
EC AND R INADALE (SQ4)	21.8	220.0	220.0	50.7	50.7
FPL ENERGY TEXAS KEIR LLC (QSE)	19.6	193.1	193.1	46.7	46.7
J ARON AND COMPANY (SQ1)	24.6	190.2	190.2	46.1	46.1
NEXTERA ENERGY POWER MARKETING LLC (SQ2)	19.9	200.7	200.7	45.4	45.4
SHERBINO I WIND FARM LLC (QSE)	24.7	214.7	214.7	44.7	44.7
EC AND R PANTHER CREEK III (SQ5)	25.6	211.7	211.7	44.5	44.5
EDISON MISSION MARKETING AND TRADING INC (QSE)	23.2	203.1	203.1	43.7	43.7
AMERICAN ELECTRIC POWER SERVICE CORP (SQ3)	19.4	213.7	213.7	42.8	42.8
INVENERGY TURKEY TRACK (SQ5)	21.8	211.5	211.5	42.8	42.8
EC AND R PYRON (SQ3)	30.0	206.2	206.2	40.7	40.7
NRG TEXAS WIND (SQ1)	32.5	191.8	191.8	38.5	38.5
LUMINANT ENERGY COMPANY LLC (SQ2)	26.4	215.2	215.2	36.2	36.2
NEXTERA ENERGY POWER MARKETING LLC (SQ1)	31.2	184.3	184.3	35.8	35.8
EC AND R PANTHER CREEK (SQ2)	32.6	197.5	197.5	34.4	34.4
TRQ8 (SQ8)	41.2	225.5	225.5	26.3	26.3
NEXTERA ENERGY POWER MARKETING LLC (SQ3)	46.7	178.0	178.0	25.8	25.8
DUKE ENERGY OHIO INC	38.9	179.0	179.0	25.3	25.3
NEXTERA ENERGY POWER MARKETING LLC (SQ4)	51.2	196.0	196.0	24.6	24.6
BARTON CHAPEL WIND LLC (QSE)	34.2	217.7	217.7	23.6	23.6
DIRECT ENERGY LP WTU (SQ2)	60.2	204.6	204.6	22.3	22.3
CPS ENERGY WIND (SQ1)	55.2	257.5	257.5	18.0	18.0
LUMINANT ENERGY COMPANY LLC (SQ1)	67.2	230.0	230.0	12.8	12.8

Avg SCE is unadjusted

SCPS1 - 1 minute regulation performance criteria, adjusted passing score 100% per Protocol 6.10.5.3

SCPS2 - 10 minute regulation performance criteria, adjusted passing score 90% per Protocol 6.10.5.3

Adjustments and exclusions applied to Adjusted SCPS scores per Protocol 6.10.6