

IRO-009-2

Eryn Lorcher
Compliance Engineer III
March 28, 2016

IRO-009-2

- Approved by FERC Letter Order on December 4, 2015
- Enforcement date: January 1, 2016
- Retires IRO-009-1

Purpose Statement

To prevent instability, uncontrolled separation, or cascading outages that adversely impact the reliability of the interconnection by ensuring prompt action to prevent or mitigate instances of exceeding Interconnection Reliability Operating Limits (IROLs).

Reason for the Standards Development Project

IRO-009-2 is a result of a periodic review of existing IRO standards.

The five-year review team made recommendations for revisions to several standards.

Change Summary

Combines R1
& R2

Clearly defines
applicable
entities and the
specific actions
required

Removes
unnecessary
language

No glossary
terms were
revised

Requirement R1:

- Revised this requirement by combining R1 and R2 to form one requirement with two subparts

Requirement R2 (previously Requirement R3):

- The IRO SDT revised the language of this requirement to improve clarity as well as consistency

Requirement R3 (previously Requirement R4):

- removed the term “without delay”
- revised the language of this requirement to improve clarity as well as consistency

Requirement R4 (previously Requirement R5):

- revised the language of this requirement for clarity as well as consistency
- clarifying language to limit applicability to appropriate affected RCs

For Further Reading

[IRO-009-2](#)

[Implementation Plan IRO-009-2](#)

[NERC Petition IRO-009-2 and FERC Letter Order Docket No. RD15-7-000](#)

Questions

