

Texas RE Spring Standards, Security, & Reliability Workshop



AGENDA

- Welcome and Instructions
- Executive Welcome
- IBR Registration
- IBR Risk Elements
- IBR Modeling Challenges
- Preparing for Audits and Self-Reporting
- Low Impact BES Cyber Systems
 <u>Risk Elements</u>
- <u>Physical Security Emerging</u> <u>Risks and Considerations</u>
- High Frequency Conduct and Change Management
- NERC Standards Abeyance
 Process

April 23, 2025

To submit questions during the workshop, please visit **slido.com** and enter today's participant code: **TXRE**

	© Q&A	∣ Polis	
Type your question			\odot
			160
8 Your name (option	nal)		Send

Welcome & Instructions



Matthew Barbour Texas RE Manager, Communications & Training





Texas Reliability Entity, Inc. (Texas RE) strictly prohibits persons participating in Texas RE activities from using their participation as a forum for engaging in practices or communications that violate antitrust laws. Texas RE has approved antitrust guidelines available on its website. If you believe that antitrust laws have been violated at a Texas RE meeting, or if you have any questions about the antitrust guidelines, please contact the Texas RE General Counsel.

Notice of this meeting was posted on the Texas RE website and this meeting is being held in public. Participants should keep in mind that the listening audience may include members of the press, representatives from various governmental authorities, and industry stakeholders.



In case of emergency, evacuate through the nearest door

Rally point is in the front parking lot







To submit questions during the workshop, please visit **slido.com** and enter today's participant code: **TXRE**



Ē
160
Send





Training Page



COMPLIANCE ENFORCEMENT

HOME | ABOUT US | CAREERS

TRAINING

REGISTRATION RELIABILITY SERVICES STANDARDS



Texas RE offers training on a ve Workshops and seminars are a Information mailing list. To sub Mailing Lists.

For questions about training, puse co

Workshops 🗸

Talk with Texas RE 🗸

Align Training 🗸

Lessons Learned 🗸

Archived Presentations ~



ty of compliance- and standards-related topics. ounced to subscribers of the Texas RE tibe to our mailing list please visit Texas RE

ing, p se contact Texas RE Information.



Archived Presentations 🗸

All of Texas RE's outreach activities are free and open to the public. Past presentations delivered by Texas RE staff are available here. Please be aware that presentations will not be available indefinitely, and may be removed to comply with Texas RE's document retention policy.



Align Release 1 Training | Recording Align Release 2 Periodic Data Submittal Training | Recording Align Release 2 TFE and Self-Certification Training | Recording Align Release 3 Training | Recording Align Release 4 & 4.5 Training | Recording

Workshops

Women's Leadership in Grid Reliability and Security Conference | Recording Understanding New Generator Obligations | Recording



2024 Fall Standards, Security, and Reliability Workshop | Recording



Spring Standards, Security, and Reliability Workshop

2025 Spring Standards, Security, and Reliability Workshop



This workshop is accredited for five Minimum Continuing Legal Education (MCLE) hours. To receive credit you may either:

- Self-report the MCLE course number
 - **174278760**

<u>OR</u>

- Email Information@texasre.org your attendee information
 - Name
 - Bar Card Number
 - Hours Attended





Upcoming Texas RE Events









Social Media



/texas-reliability-entity-inc

@Texas_RE_Inc

/TexasReliabilityEntity



Executive Welcome



Joseph Younger Texas RE Vice President & Chief Operating Officer







IBR Registration

Katie Van Zee Director, Enforcement and Registration

April 23, 2025

NERC IBR Strategy





Regulatory Enhancements

Two Projects Moving Contemporaneously



IBR Registration, FERC Order issued November 17, 2022



10

NERC IBR Quick Reference Guide

NERC

NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION

Quick Reference Guide: IBR Registration Initiative

March 2025

As part of its Inverter-Based Resource Strategy, NERC is dedicated to identifying and addressing challenges associated with inverter-based resources (IBR) as the penetration of these resources continues to increase. ERO Enterprise assessments identified a reliability gap associated with the increasing integration of IBRs as part of the grid in which a significant level of bulk power system-connected IBR owners and operators are not yet required to register with NERC or adhere to its Reliability Standards.

In response, FERC issued an order in 2022 directing NERC to identify and register owners and operators of currently unregistered bulk power system-connected IBRs. Working closely with industry and stakeholders, NERC is executing a FERC-approved work plan to achieve the • ERO Enterprise IBR Event Tracking Graphic Resources are also posted on the Registration page of the NERC website.



Key Activities

 NERC submitted its <u>quarterly work plan update</u> to FERC on February 5.

• NEW NERC has released a guide—Reliability Standards Compliance Dates for Generator Owners & Generator Operators-providing finalized and pending Reliability Standard compliance dates applicable to Category 2 registration.

Available Resources

- ERO Enterprise CMEP Practice Guide
- 101 Resource Document | IBR Video | Open Letter to New Registrants
- Q1 2024 Update | Q2 2024 Update | Q3 2024 Update | Q4 2024 Update
- NEW ERO Enterprise March 2025 Webinar: Slide Presentation and Recording
- ERO Enterprise November 2024 Webinar: Slide Presentation and Recording
- Quick Reference Guide: Candidate for Registration
- **NERC Registration Page**
- Standards Under Development Page | Milestone 3 Summary and Infographic

RELIABILITY | RESILIENCE | SECURITY





IBR Registration Timeline





ROP Changes

"Generator Operator" (GOP) means the entity that: 1) operates generating Facility(ies) and performs the functions of supplying energy and Interconnected Operations Services (Category 1 GOP); or 2) operates non-BES inverter based generating resources that either have or contribute to an aggregate nameplate capacity of greater than or equal to 20 MVA, connected through a system designed primarily for delivering such capacity to a common point of connection at a voltage greater than or equal to 60 kV (Category 2 GOP).

"Generator Owner" (GO) means an entity that: 1) owns and maintains generating Facility(ies) (Category 1 GO); or 2) owns and maintains non-BES inverter based generating resources that either have or contribute to an aggregate nameplate capacity of greater than or equal to 20 MVA, connected through a system designed primarily for delivering such capacity to a common point of connection at a voltage greater than or equal to 60 kV (Category 2 GO).









RFI 1 – Gathering Contact Information

Contact Information

- RFI sent to all Transmission Owners and Balancing Authorities
- Identification of facilities
- Contact information for owners and operators of those facilities



Necessary Data for Registration

- GO/GOP Asset Verification Form
- One-Line Diagram(s)
- Interconnection Agreement
- RARF/RIOO Information
- Third-Party Agreement(s), if applicable



Webinar 1: Inverter-Based Resource Registration Initiative

- Webinar Recording
- <u>Slide deck</u>

Webinar 2: Application of the Registration Criteria for Category 2 Generator Owner and Generator Operator Inverter-Based Resources

- Document
- Webinar Recording
- <u>Slide Deck</u>



ERO Enterprise Registration Procedure

ERO Enterprise Entity Onboarding Checklist

ERO Enterprise 101 Informational Package

CORES End User Guide

Texas RE Reliability 101 and 201 Webinar Series

Understanding New Generator Obligations | Recording





Compliance Obligations Expected to Begin May 2026

Reliability Standards Compliance Dates for Generator Owners & Generator Operators

Order 901 Standards Development





Regulatory Enhancements

Two Projects Moving Contemporaneously

IBR Standards Project, FERC Order 901, issued October 19, 2023

IBR Registration, FERC Order issued November 17, 2022



IBR Data Sharing

IBR Model Validation

IBR Planning and Operational Studies

IBR Performance Requirements





IBR Standards Work Plan



Standards Development Mapping of FERC Order 901 Directives and Other Guidance to Standards Development Projects, Draft SARs, and Pending SARs





25

Get Involved with the Standards Process

NERC Standards Review Forum (NSRF)

• Texas RE stakeholder group to discuss upcoming effective standards as well as compliance topics

Reliability and Security Technical Committee (RSTC)

• NERC stakeholder committee to discuss various grid topics

Standard Drafting Team (SDT) Meetings

Open meetings to participate in the standards development process









Questions?





IBR Risk Elements: FAC-001-4 and FAC-002-4

Alexandra Huey O&P Compliance Engineer

Rashida Caraway Manager, Risk Assessment

Slido Question

Does your registered entity have any IBR assets?

A. Yes B. No







30

An inverter is a power electric device that converts direct current (dc) electricity to alternating current (ac) electricity.



*ERCOT Report on Existing and Potential Electric System Constraints and Needs, December 2024





Purpose of FAC-001 and FAC-002

Risks of FAC-001 and FAC-002

Entities and the Risks

Compliance Engagement Approach

Impacts of IBRs related to FAC-001 and FAC-002

CMEP Feedback Loop







Slido Question

Who is FAC-001 applicable to? A. Transmission Owners B. Generator Owners C. Distribution Providers D. Both A & B







Purpose: Ensures reliability of the Bulk Electric System (BES) by requiring Transmission Owners (TOs) and applicable Generator Owners (GOs) to have documented Facility interconnection requirements and make requirements available so that entities seeking to interconnect will have necessary information

- Update Facility interconnection requirements and make them available
- Facility interconnection requirements address the following: new interconnections or existing interconnections with a qualified change (TO only), notifying and confirming responsible parties





Slido Question

What kind of study does FAC-002 require?







36
Purpose: Ensures that entities conduct adequate interconnection studies before connecting new or changed Facilities and assess the impact to the BES

Transmission Planner (TP) and Planning Coordinator (PC) shall study the reliability impact interconnecting new Facilities and existing interconnections

GO, TO, and Distribution Provider (DP) shall coordinate and cooperate on studies with TP or PC

PC shall maintain publicly available definition of qualified change





Focus remains on IBRs due to their increasing grid presence

Ensures reliable integration

Need for identifying and mitigating potential reliability risks

Avoids reliability issues related to improper modeling or operational expectations







38

Specific Risks

Operational Risks

- Widespread issues affecting large portions of the grid system stability
 - Voltage issues, frequency response
- Potential system instability or cascading failures from inadequate integration
 - Incorrect models used in the study is a concern
 - Models used in the study must represent the behavior of the resources in real-world installations



Registration Function(s)

Inherent Risk

- New resources connected to system
- Planned facilities
- Transmission portfolio
- System modifications

Performance Risk

- System events
- Compliance history





Long-Term Studies/Assessments Risk Category

- Planning horizons are used to evaluate whether the system can reliably operate in Real-time
- Failure to do so will likely result in gaps and may compromise the integrity and reliability of the BPS





Table 7: Inverter-Based Resources							
Rationale	Standard	Req	Entities for Attention				
Clear and consistent interconnection requirements for IBRs	FAC-001-4	R1, R2	Generator Owner Transmission Owner				
IBRs being adequately studied	FAC-002-4	R1, R2	Generator Owner Planning Coordinator Transmission Planner				





Federal Energy Regulatory Commission (FERC) Order No. 2023

Facility Interconnection Requirements and Availability



**Explainer on the Interconnection Final Rule*, www.ferc.gov, January 2025





IBR Risk Elements: FAC-001-4 and FAC-002-4

The rule lays out how FERC will reform processes used by transmission providers to study and connect generating facilities to the transmission system with three key components:

- Transitioning from a first-come-first-serve serial process to a first-ready-first-served cluster study process
- Increase the speed of interconnection queue processing
- Reforms to incorporate technological advancement in the interconnection process





Facility Interconnection Requirements and Availability

Ensure Facility interconnection requirements are documented

 Interconnection requirements shall address procedures for coordinated studies for new interconnections or existing interconnections seeking to make a qualified change

Ensure Facility interconnection requirements are available

Generation Interconnection Process Overview

The generation interconnection process described in this handbook has been divided into the following three stages for the purpose of defining the interactions between the developer/owner of the generation resource, ERCOT and TSPs:

Stage 1: Interconnection Request Application to Quarterly Stability Assessment

- Stage 2: Registration and Modeling
- Stage 3: Energization, Synchronization and Commissioning

Figure 1: Generation Resource Interconnection Process Flow



ERCOT's Resource Integration Guides









Entity Coordination

Coordination, internally and externally (including third-party suppliers and contractors) before making changes to the system that have the potential to affect another entity and Bulk Power System (BPS) reliability and security

Resolve issues that could negatively affect system performance

Determine what constitutes a qualified change

Ensure timeliness of data submissions and reliability impact studies

Coordinate and provide data for reliability impact studies





IBR Risk Elements: FAC-001-4 and FAC-002-4

Ensure that all necessary studies for IBR connections are being performed (FAC-002 R1)

- Are IBRs explicitly addressed in the entity's interconnection study process?
- How does the entity ensure study assumptions and system performance considerations are adequate when determining the reliability impact of new IBR interconnections?
 - What is the review or approval process?
- To evaluate system performance:
 - Steady-state analysis, include IBRs
 - Dynamic stability analysis, evaluate behavior of IBRs during faults and frequency events
 - Short-circuit analysis, evaluate fault current contributions from IBRs





5.2 General Provisions

5.2.1 Applicability

- (1) The requirements in Section 5, Generator Interconnection or Modification, apply to the following:
 - (a) Any Entity proposing to interconnect any generator with an aggregate nameplate capacity of one MW or greater, including but not limited to any Generation Resource or Energy Storage Resource (ESR), to the ERCOT System;
 - (b) Any Entity proposing to interconnect a Settlement Only Generator (SOG) to the ERCOT System; or
 - (c) Any Resource Entity seeking to modify a Generation Resource, ESR, or SOG that is connected to the ERCOT System by:

PUBLIC

ERCOT PLANNING GUIDE - DECEMBER 12, 2024

5-1

SECTION 5: GENERATOR INTERCONNECTION OR MODIFICATION

- Increasing the real power rating from that shown in the latest Resource Registration data by one MW or greater within a single year;
- (ii) Changing the inverter, turbine, generator, or power converter associated with a facility with an aggregate real power rating of ten MW or greater, unless the replacement is in-kind;



Modifying any control settings or equipment of Inverter-Based Resources (IBRs) that impact the dynamic response (such as voltage, frequency, and current injections) at the Point of Interconnection (POI) in a manner that is deemed to require further study in accordance with the process outlined in paragraph (5) of Section 5.5, Generator Commissioning and Continuing Operations;

- Changing or adding a POI to a facility with an aggregate real power rating of ten MW or greater; or
- (v) Increasing the aggregate nameplate capacity of a generator less than ten MW to ten MW or greater.

Implementation Guidance for FAC-002-4, R6

Modifying any control settings or equipment of inverter-based resources (IBRs) that impact the dynamic response (such as voltage, frequency, and current injections) at the Point of Interconnection (POI) in a manner that is deemed to require further study in accordance with the process outlined in paragraph (5) of Section 5.5, Generator Commissioning and Continuing Operations ERCOT Planning Guide



CMEP Feedback Loop



Resources and Guidance

Texas RE website

- Engagement common questions
- Training materials

ERCOT website

- <u>Resource Interconnection Handbook</u>
- ERCOT Planning Guide

NERC website

One Stop Shop





Questions?





Texas RE Spring Standards, Security, & Reliability Workshop



AGENDA

- Welcome and Instructions
- Executive Welcome
- IBR Registration
- IBR Risk Elements
- IBR Modeling Challenges
- Preparing for Audits and Self-Reporting
- Low Impact BES Cyber Systems
 <u>Risk Elements</u>
- <u>Physical Security Emerging</u> <u>Risks and Considerations</u>
- High Frequency Conduct and Change Management
- NERC Standards Abeyance
 Process

Return at: 10:45 am

To submit questions during the workshop, please visit **slido.com** and enter today's participant code: **TXRE**

	🖓 Q&A	III Polls	
Type your question			Ĵ
			160
8 Your name (optio	nal)		Send



IBR Modeling Challenges

Brad Woods Senior Reliability Engineer

Blair Giffin Manager, O&P Compliance Monitoring

Growth of Inverter-Based Resources (IBRs) in ERCOT





IBR Modeling Challenges

55

Growth of IBRs in the U.S.









IBR Modeling Challenges

56

Transformation in Frequency Control



Source: NREL: Inertia and the Power Grid: A Guide Without the Spin





57

System Design (Frequency)

System is designed to operate at 60 Hz

Frequency depends on the balance between load and generation during both normal and contingency conditions

Generation must remain connected to the grid and continue to support grid frequency during disturbances

Frequency deviations larger than +/-0.05 Hz from 60 Hz can lead to cascading failures or system instability



Source: NERC Balancing And Frequency Control





Synchronous Generation vs IBRs

What are the differences between inverter-based resources and synchronous generation?

Both inverter-based resources and synchronous generation can provide essential reliability services to the BPS. However, the industry is facing challenges integrating significant levels of inverter-based resources because of the unique differences between technologies. BPS planning, design, protection, and operations practices will all need to evolve to ensure reliability and resilience of the BPS under this rapid pace of change.

Differences between Inverter-Based Resources and Synchronous Generation				
Inverter-Based Resources	Synchronous Generation			
• Driven by power electronics and software	Driven by physical machine properties			
No (or little) inertia	Large rotating inertia			
Very low fault current	High fault current			
Sensitive power electronic switches	Rugged equipment tolerant to extremes			
Very fast and flexible ramping	Slower ramping			
Very fast frequency control	Inherent inertial response			
Minimal plant auxiliary equipment prone to tripping	Sensitive auxiliary plant equipment			
Dispatchable based on available power	Fully dispatchable			
Can provide essential reliability services	Can provide essential reliability services			





Source: 2023 NERC Guide Inverter-Based-Resources





Source: NREL

Key Components of IBR Models

- **Energy source:** Models the individual inverter-based resources like solar PV, wind turbines, or battery energy storage system
- Inverter: Models the power electronic device that converts the dc electricity into ac electricity, the software controls that dictate how the resource responds to grid events, and the inverter protections including overvoltage, bus voltage unbalance, and overfrequency/underfrequency.
- Step-up transformer: Models the transformers that step up or down the voltage for connection to the grid
- **Collector system/feeders:** Models the electrical network connecting the energy sources to the plant substation and protections for feeders
- Protection Systems: Models for various protections including overcurrent, low voltage/high voltage, DC Bus, PLL loss of synchromism, phase jump, and DC reverse current
- Control Loops: Models the inner current control loops and outer power/voltage control loops to regulate the IBR's output and interaction with the grid
- Plant controller: Models the central controller that manages the overall operation of the IBR plant, including grid support functions
- □ **Plant substation:** Models the buses where the collector system feeders aggregate and connects to the step-up transformer
- □ **Tie-line:** Models the tie line connecting the IBR plant to the bulk power system







IBR Models Provided to Transmission Planners

When Planners Receive Models Prior to Commercial Operation

- Interconnection Study
- Can be 1-5 years before commercial
- Models provided represent the expected design (may not be site specific)
- Commissioning
- Less than one year before commercial
- Match control settings at the plant (as-built)

Model Review by Planners

- Check model information provided by GO
- Check performance of model for usability
- Does the model work?
- Check performance of model during disturbance simulations
- Model behaves as expected
- No ability to compare performance of models with plant during disturbances
- Behavior of model vs plant

Commercial Operation

- Latest version of models used for planning studies
- Should represent expected behavior during disturbances





Why Accurate IBR Models Are Important for Planning

Growth of IBRs is Significant and IBRs are Needed for Frequency Control

IBRs are Different from Synchronous Generators

IBR Behavior During System Faults Needs to be Studied

Reliability Issues may not be Identified and Addressed if IBR Models are Not Accurate (Cascading / Instability)





IBR Events 2016 – 2023

NERC

NERC

1,200 MW Fault Induced Solar Photovoltaic Resource Interruption Disturbance Report

Southern California 8/16/2016 Event

June 2017









900 MW Fault Induced

Resource Interruption

Solar Photovoltaic





NERC











NERC 2022 California Battery Energy Storage System Disturbances

California Events: March 9 and April 6, 2022 Joint NERC and WECC Staff Report

September 2023







2016 – Blue Cut Disturbance

On August 16, 2016, at 10:36 a.m. Pacific, the Blue Cut fire began in the Cajon Pass. The fire quickly moved toward an important transmission corridor that is comprised of three 500 kV lines and two 287 kV lines. By the end of the day, the transmission system experienced thirteen 500 kV line faults and two 287 kV faults as a result of the fire.

- IBR generation loss: approximately 1,200 MW was the largest
- IBR generation loss caused by:
 - Protection settings
 - Momentary cessation
- Lowest frequency = 59.867 Hz
- IBR models were **not** accurate



Figure 1.3: Utility-Scale Solar PV Output in SCE Footprint on August 16, 2016





GOs

 Inverters that momentarily cease active power output for these voltage excursions should be configured to restore output to predisturbance levels in no greater than five seconds, provided that the inverter is capable of these changes

PCs and TPs

- Models used for interconnection-wide case creation should use the NERC List of Acceptable Models. Particularly, solar PV facilities should be modeled using the latest generic model with parameters that are representative of the actual installation. These should include representative values for momentary cessation and tripping based on actual installed settings
- More detailed (e.g., user-defined, vendor-specific, etc.) positive sequence models should be used by the local TP for generation interconnection studies
- In some situations, particularly under weak grid conditions, detailed electromagnetic transient (EMT) models should be used as necessary

	57 Hz. This	Recomm	
Froquency below Stritterted		NERC should ation 2-	
Error	in Frequence system frequence the transient of outside	inverter continue to	
anect Due to Lited du	ue to a percent frequency during interpreter western	than 1.1 new connected resource form furth	
A. DV Discontres discontree	instantaneous inverter manual pRC-024-2 for the inverters	reactive, positive of current of determine	er, in-depth and
Finding 1: For solar PV resource and the PLL indicating a melopmen	it owner and table in s7 Hz. Therefore, the	Positive - negative	ine if that should be more
A significant amount was due to the The solar develop are	a. The field or less than 57	Rec-	equired, the allowed of cessari-
perceived frequency and as less than 57 has a musicity	icy equal to	Morendatio	ce) should be analysis should for voltages to with higher
waveform period 2 no-trip curve trantaneous trip for the gueno	y of 57 has a corrective action	affected bench	be injected at which determine which has 0.9 not
of the PRC-024-2 indicates instantunon seeing a new	to develop a conhigh frequency	momonic entities to marking st	what voltage low of an unit or great
Interconnection instantaneously of	tion collaboratively second delay to the during transient	benchmentary cessation determine the	ies and anal
were set to trip	ire working and a two wave distortion	Caused in arking effort	extent to should be
and the affected entry fre	quency to prodump and sine we	condition by momenta explore his	ould pose which these performed
Action 1 manufacturer and time delay for its	a to phase in the	amount Once a mov cessation	penetration potential resource by the ERO
The inverter ment a five-second frequency tripping	a sutside the frequency	these commentant detailed out	tripping of Solar PV Conduct WECC should loss event
plan to implemente incorrect	add clarity that outside	resource to additions, the Miss addition and	tification of these resources and these conduct a me
tripping to an system.	to be revised to act trip area.	Et al loss protection	or tripping potential inces due to the potential for
faults on the strength	seeds to be and not a musicity	rinding 3. No	ubcommission well as the start has been a transmission
mendation 1a	uipment) of trequents	This disturbance NERC Alout	led to prote should compared inverter-bared in system fault
Recommend review PRC-02 lif needed to protect	delay for the lowest	development in analysis his history	protect interconnection whether whether including the
NERC should a may trip area (hand be a required occur,	the industry to all intercompany inghts an unit	return from
curves are a the semine if the	ere should a for	power system	Potenti in Potenti to the
mendation 10	ough.	Anti the potential soft	his disciplination of the second
Recommend review pactored waveform	to Low Voices active curve	NEDG 3	Sprand Annual
NERC Shoe transient/distort	on Due to momentarily	riske Event Analysis	solar resources needs to be proliferation
to ensure	are configured that for	Data discussed here is developing	orce loss during widely come of solar
1ing 2: Momentalled inverter	decline potential	potential changer to and to ensure NERC alors in	transmission c
Finding of currently in or below 0.9 per	Simulation Ober frequency 200 MW of the inject	A Page 10 NERC Reliation that they	he in faults on the
The majority 1.1 per unit of	The following in Observations and Takonus	Commendation and and and and and and and and and an	id the in a
voltages and the storter	SCE:	ays	a cone steps that row to encour
2 horted for the West	and any are provide	ed based on the circulat	considered. So be taken to a source they are
Action 2	These simulation	the simulations performed by WECC and	d mitigate there of the
Simulation momentarily come identified as a	Southwest	, incee an	u se risks while
inverters d resources were mission fault.	used western portion of the WECC puster	potential effects of pu	aware of
connected for a transmission	used various levels of momentany second under his	gh penetrations of color momentary cessation in the	ces. This at
active currer 24	settings could impact reliability cessation (and tr	ipping) thresholds to solar PV inverters. The simulation	ry cessation should include changes
mendation 24 cease activ	today; rather, it is to study the goal is not to	characteries to understand how these investor	and take a recome
Recommentation disturbance leve	condition. condition condition condition	litions and how the inverters behave as inverter	appropriate mendation
Inverter output to pre-dist		and any reliability risks associated	tter
restore changes.	Utility-scale solar PV facilities	with those	Un anufacturere
these charter 2h	availability and access to tree often located in	Centralized	ng st. National are often to
mmendation 20-024-2 to	groups. As a result above to transmission facilities also	tend to	to the existing leng Electrical Country Potential
Recombould review provinces is no	plants because these in ormal voltage conditions cau	red to cause solar PV plants to doubles. Land	system, ar 1547 Stander, GIAs, and
NEKC site connected resources	to increase control	sed by faults can impact large amount	isfull
inverter ve	Could note a control settings that do not support nos	en plants. As the penetration of solar PV	Brow promulgated a UL line control
Recommendicated by	reliability risk. Tripping for voltage	eliability (e.g., 0.9 pu voltage	intercome Coordinate for their
It has been mould ner	 The recovery rame sets of 	e 0.5 pu should be available momentary cessation)	ected to the with UL such
(40 percent) woltages	performance of the after momentary cessation by	ond be avoided.	transmission
injection for	the extent and the BPS. Longer ramp rates should be	as a significant impact on the free	ite
and clarify '	disturbance of Typical maximum values at	avoided, and ramp rater charled requency response	tion (NEPA)
NERC should be	le a set bance output. However, inverter manuf	not exceed 3-5 seconds should be minimized to	ton may be to and state include
	re.g., return to pre-disturbance output in	ave stated that there are fully recover to pre-	transmission pur a standictions to
	 As the allowed and 	s).	system. standard that is
	to penetration in momentary cessation voltage increase		- 6
	a wide	he amount of invertor man	
	a wide area; whereas a momentany amomentan	ry cessation voltage of a momentary cessation (due	
	Related to modeline at	wer than 0.5 million of 0.9 pu has an impact over	
	the following takeawaye and	that 0.5 pu has significantly smaller imposed	
	 Models used for interconstructions are made: 	impact,	
	Particularly, solar py facility	hould	
	are representative racilities should be modeled using	inouid use the NERC List of Acceptable to	
	momentary council of the actual installation The	s the latest generic model with passed Models ²⁰ .	
	the station and tripping, accordingly, the	se should include representation	
	 More detailed (e.g., user de la	on actual installed settings	
	the local TP for generation wendor-specific etc	l postal	
	 In seneration interconnection studies 	positive sequence models should be	
	in some situations, particularly under	billion be used by	
	models should be used as paceased weak grid condition	ons detailed -	
	as necessary.	of the electromagnetic transient (chart	
		(EMT)	



2017 – Canyon Disturbance

On October 9, 2017, the Canyon 2 Fire caused two transmission system faults near the Serrano substation east of Los Angeles. The first fault was a normally cleared phase-tophase fault on a 220 kV transmission line and the second fault was a normally cleared phaseto-phase fault on a 500 kV transmission line. Both faults resulted in the reduction of solar PV generation across a wide region.

- IBR generation loss: Approximately 900 MW
- IBR generation loss caused by:
 - Protection settings
 - Momentary cessation
- Lowest frequency = 59.878 Hz
- IBR models were **not** accurate







Figure 1.7: Western Interconnection Frequency during Second Fault





Blue Cut – Causes and Recommendations

GOs

- The use of momentary cessation is not recommended, should not be used for new inverter-based resources, and should be eliminated or mitigated to the greatest extent possible for existing resources connected to the BPS
- Existing inverters where momentary cessation cannot be effectively eliminated should not be impeded from restoring current injection following momentary cessation
- Voltage protection functions in the inverters should be set based on physical equipment limitations to protect the inverter itself and not based solely on the PRC-024-2 voltage ride-through characteristic. Within the "no trip" region of the curve, the inverters are expected to ride through and continue injecting current to the BPS. The region outside the curve should be interpreted as a "may trip" zone and not a "must trip" zone and protection should be set as wide as possible while still ensuring the reliability and integrity of the inverter-based resource
- Inverters should not trip for momentary PLL loss of synchronism caused by phase jumps, distortion, etc., during BPS grid events (e.g., faults)

PCs and TPs

- EMT studies should be performed by affected GOPs in coordination with Transmission Owners (TOs) to better understand the cause of transient over-voltages resulting in inverter tripping
- Generic dynamic stability models used during the interconnection process for studying reliability of the BPS do not accurately reflect all aspects of the behavior of inverterbased resources. Model improvements should be prioritized by industry groups developing these models (e.g., WECC Renewable Energy Modeling Task Force) to ensure that stability models sufficiently reflect the behavior of inverter-based resources installed today and in the future





2018 – Angeles Forest and Palmdale Roost Disturbances

The Angeles Forest disturbance occurred on April 20, 2018, and was initiated by a 500 kV transmission line fault with a failed splice. The resulting phase-tophase fault was cleared normally by line relay protection in 2.6 cycles.

Palmdale Roost disturbance occurred on May 11, 2018, and was initiated by a 500 kV transmission line fault due to insulator flashover caused by a buildup of bird nesting material. The resulting single-line-toground fault was cleared normally by line relay protection in three cycles.

- Angeles Forest IBR generation loss: approximately 900 MW
- Palmdale Roost IBR generation loss: approximately 900 MW
- IBR generation loss caused by:
- Protection settings
- Momentary cessation
- Lowest Frequency = 59.86 Hz
- IBR models were **not** accurate



7:00:00 8.00.00 16.00.00 17.00.00 18.00.00 19.00.00

TIme

April 20, 2018 ----- May 11, 2018



Figure 1.21: System Frequency during Both Disturbances [Source: FNET]



Recommendations

GOs

- Use of momentary cessation is not recommended, should not be used for new inverter-based resources, and should be eliminated or mitigated to the greatest extent possible for existing resources connected to the BPS
- Existing inverters where momentary cessation cannot be effectively eliminated should not be impeded from restoring current injection following momentary cessation
- Work with inverter manufacturers to set transient ac overvoltage protection as wide as possible while still protecting the integrity of the inverter and associated equipment
- Coordinate with inverter manufacturer to ensure that dc reverse current detection and protection are set to avoid tripping for dc reverse currents that could result during sub-cycle transient overvoltage conditions

PCs and TPs

- Ensure that momentary cessation of BPS-connected solar PVs is modeled correctly
- Follow up with applicable GOs to ensure that these changes are being made and that models are being updated to accurately reflect the dynamic behavior of solar PV resources connected to the BPS





2020 – San Fernando Disturbance

On July 7, 2020, the static wire on a 230 kV double circuit tower failed, causing a single-line-to-ground (SLG) fault on both the #1 and #2 parallel circuits. The fault was cleared normally in about three cycles. In addition, a nearby 230 kV line relay incorrectly operated for an external fault. For this first fault event, approximately 205 MW of power reduction was observed at BPS-connected solar PV facilities in the Southern California region. At 11:41 PDT, the #1 circuit was reenergized and held; however, at 11:41:31, the #2 line was re-energized and relayed back out. The cause of relaying back out was a low-impedance three-phase fault that was cleared normally in 2.3 cycles.

- IBR generation loss: approximately 1000 MW (second fault)
- IBR generation loss caused by:
- Lowest frequency = 59.84 Hz
- IBR models were **not** accurate



Figure 1.4: CAISO BPS-Connected Solar PV during Disturbance [Source: CAISO]



Figure 1.10: FNET Frequency Measurements for Event #2 [Source: UTK/ORNL]



Recommendations

GOs

- All GOs and GOPs should ensure adequate data monitoring within their facilities for inverter-based resources to determine root causes of abnormal performance to BPS disturbances. This includes having access to inverter and plant-level settings, fault codes, oscillography records, digital fault recorder data, and archived plant data (i.e., SCADA data) with a resolution of one sample per second or faster. NERC Standards should be enhanced to ensure this data is available from all BPS generating facilities, as this continues to be a major issue limiting the ability to perform event analysis
- Should analyze partial tripping events and work with inverter manufacturers to mitigate inverter tripping to the extent possible
- Should ensure that any changes to plant-level settings, inverter settings, or facility topologies or ratings should be provided to the TP

PCs and TPs

- Ensure that the models provided during the interconnection study process are able to account for all forms of tripping by IBRs. This may require the collection of EMT models and the evaluation of system performance with EMT studies
- All models should be updated after plant commissioning and checked to ensure that the model matches the as-built, plant-specific settings, controls, and behavior
- All models should be updated after GOs make settings changes to inverters that affect its electrical output during steady-state or dynamic conditions





2021 – Odessa Disturbance

On May 9, 2021, a single-line-to-ground (Phase A) fault occurred on a generator step-up (GSU) transformer at a combined-cycle power plant near Odessa, Texas. The fault was caused by a failed surge arrester at the combustion turbine (CT) during startup for testing. The circuit breaker for CT1 operated and cleared the fault within three cycles and the #2 unit experienced a partial trip followed by a run back for a total loss of 192 MW. The fault caused voltages in the area to drop to 0.72 pu at the 345 kV connecting station for the generation facility, 0.84 pu around Fort Stockton at a 138 kV station, and as low as 0.54 pu at a 69 kV bus near Alpine, Texas. Voltage in the area recovered to near predisturbance levels very quickly (within a couple electrical cycles) after the fault cleared.

- IBR generation loss: approximately 1100 MW
- IBR generation loss caused by:
- Lowest frequency = 59.805 Hz
- IBR models were not accurate



Figure I.5: ERCOT BPS-Connected Solar PV during Disturbance [Source: ERCOT]



Figure I.6: System Frequency during Event [Source: UTK/ORNL]




Recommendations

GOs

• Should adopt the performance recommendations provided in the NERC reliability guidelines

PCs and TPs

- High quality, vendor-specific EMT models are needed to identify the causes of tripping
- EMT studies should be required as part of the interconnection study process to ensure that all resources can reliably operate once connected to the BPS prior to the resource being interconnected
- Enhance modeling requirements to ensure that the causes of tripping can be accurately represented in studies prior to interconnection
- Assess the quality and fidelity of the positive sequence and EMT models provided during the interconnection study process
- Benchmark the positive sequence models and the EMT models against each other to ensure that all models are reflective of the as-built settings, controls, and protections that are installed
- Conduct a system-wide model validation effort to identify models that do not match actual performance of the installed facilities

				t recources			
			incues of im	verter-based resource t	b		
		eboormal p	erformance issues being	adequately bants state	d	6	
		udentifying abliability	guidelines are based to	chnology involved			
Key Finding	ry is not pr	Key Finding		heresou	mitigated		
In many case, the rec	ommenda	Data provided by affected sola	ar PV for	theing property	to prohibi		
Furthermoliable oper	ation of the	NERC and the Regional F	in ksues	are not arequirements	t is th	of temperature	
ensure rentigating a	ctions are	he a co	and these interco	nnection	nt- iber	ult Land man	nalyzed by
that no event.		lace of synchro	not establishing	inverter and plu	the be	ing solution a	surement
theers		on PLL loss and PC, are	tion cal	ised by incal response of	ould N	ERC helpful f	or overall
Vev Findin	B contin	Key Finding	level protection The	electric These issues	able	is. Only	One plant
Solar PV P	ordination	Plane	del to some degle level c	ontrounect in an un		team to	Conduct
TOS, IN CO	010.	inverter termine trip settin	gster and plans able t	0 000		hand had	on the
1108	untetti	oped on itions above into the in	the plant was	-unt events c	Ontinue te		
Key Finding	pv plant volt	ige condition programmed studies, Y	- 10	tuned with each o	ther and a	be an issue for	BPS solar
Multiple	d						reliable
level com	d Key Fin	ling	arter terminal or foodor	lough protection cours	d by invo	tor and plant	roperly
facility been in	ji iviuitipi	solar PV plants tripped on inv	erter terminaror leeder	-level protection caus	ostrical re	rter and plant-	
have -	facility	based solely on the logic prog	rammed into the invert	or and plant-level com	ectricar	issues should	
manna	have be	en identified during intercon	nection studies, yet the	e plant		an unreliable	
	manner		icetion studies, yet th	undo faul	events.		
				ng across multiple to	s setting		
			amount of tripp	e inverter at 1.5 pt	ause the		
		and a sig	nificant and-coded into th	e conditions occur	terdrives	-	
		tection has caused as to	nd is hard neak overvoltag	and ultimatery tates mi	de torne	n	
Finding	mervol	age protection manufacture	el. The phe fault clears,	bove). The up and possi	DIA B. C.		
Key Pitter-leve	lac over ver	by the invole to plant per wor	k when the las mentioned	likely persist			
The trip th	undio o m	- the action of	attaine to stoning with				
is non-col	Key Finding			ALL			
inverter	Multiple so	ar PV plants include protect	and deal	band of 60.017 Hz. A	level p	rotection that	
itstermi	are set dire	CTIV TO TO	reached the upper occur	ctive power output	ablish	requirements	
and have		frequency, frequency	urces rapidly changing	erfrequency contangear	5 024-3	was recently	
ev Finding	od recovery	of system ber of solar PV reso	er reduction to the by ERCO	T. Therefore, it opp	t mine	ry unless	
fter the fault event at	team identi	the magnitude of active por	ments set fortir of the	these facilities -	1.00	ault ith solar	
hat time, the review	Howev	er, the following the require	tation of PPR contain		using der	le to	
respor Key Finding				whose facilities and	ties are au	Nice	
does f Inverters from	n one manu	facturer are programmed +	resour	rces, theyer, some fact	turn to se	pes of	
that is open the inve	erter ac circ	uit breaker for f	inverter-based minute	s. How not have any	These the	ty and	
this n leads to the i	nverter out	uncations f	or inverter of five land P	A) did performaticies	it capaum		
ceased. This l	0.2.4	service specification on	the on the p	the BA has sum			
COP+	ding of	eturn to see most comming thes	assumptions of ensu	re the			
sup) in the	absence on	action tinter by mounty making	acted resources erid conv	Million			
auton	aticrecul	much tage plants all BPS-conne	and emergence of				
retur	n to sents an	d the clear for during norman			not be		
requ	irentions s	out the system of		A IN NERC Car	als are		
spec	Recomm	andation					
flex	FMT mor	els are expected to be the mo	ost accurate representa	tion of a resource for	use in de	tailed reliability	
	studies.	ssessments demonstrate that	EMT models are lacking	key protection and co	ntrol funct	tions within the	
4.01	models a	nd that they are unable to de	monstrate the response	of the equipment in	the field.	and this poses	_
Recommendat	significan	t reliability risks (particularly i	n areas of rapidly grow	ving penetration	erter-ba	sed resources).	
Noct of the ca	Inductry	chould develop EMT-focused	modeling and study re	and the	nent th	em in a timely	havior
1 Recomme	ndation						intity, o
All TPs and	PCs should	be assessing the quality and f	idelity of the positive se	quence and EMT mod	els provid	ed or reports	ctions t
during the	interconne	tion study process. Model qua	lity checks, test, and v	alidations should be co	nducted p	per pls. The R	STC charg
the recom	mendation	set forth in the NERC relial	oility guidelines. Any r	nodel quality concern	s should	be itigating a	ictions an
addressed	prior to th	e studies being conducted and	resources should be h	eld accountable for a	ny modeli	ing ault event	s. Withou
errors that	do not suit	able represent the installed equ	upment in the field.			also be re	Ported to
tecomm.	w identify	na causes of suchould be up	ues accurand PCs per	taline recommission	ing	oues accurate	ly capture
While the and prope	sure that	ne lity or fidelity stormance is	to all TPs and allability au	undit undit	ling		
step towents to en	dels lacking	quality of the second applies	NEBC MICH	tols and the			
requiremention. Mo	ed with th	same recommendation	cequence	models use of the			
intercol be conduct	ately. This	our cost	the positive sequels are	reneer			
should appropr		seement of both	soure that all mode		_		
Recommendation							
RCOT should condu	ct a system	wide model validation effort	to identify models the	at do not match actu	al		
performance of the in	stalled faci	ities. This study should include	event recreation for b	oth the May 9 and Jun	e		
26 events. The studies	should be	able to indicate performance is	sues identified in this re	port. Otherwise, mode	51		
mprovements are ne	eded imme	diately. ERCOT should develop	a system-wide EMT m	odel for this study th	at		
accurately represent s	system elen	ents, end-use load models, and	generating resources.	Tripping due to PLL lo	s		
of synchronism, inver	ter-level ar	d teeder-level instantaneous a	ac overvoltage protecti	on, and other sub-cyc	e		
modeling deficiencies	nerformar	ppropriately modeled in the si	rected and gans in por	log should identify an	y te		
that could lead to unr	eliable perf	ormance of these resources in	the future. Aggregate f	indings should be mad	e		
oublicly available and	should be s	hared with Texas RE, NERC, and	the NERCIRPWG				
and a second and		and a second s	in the second seco				URITY
						SEC	
						5	
						\$ "	



2021 – Victorville, Tumbleweed, Windhub, and Lytle Creek Fire Disturbances

June 24, 2021, Victorville Disturbance: A 500 kV line relayed due to a phase-tophase fault (3.5 cycle clearing).

July 4, 2021, Tumbleweed Fire Disturbance: A fire burned under some 500 kV transmission lines and heavy smoke caused faults on both the #1 and #2 lines.

July 28, 2021, Windhub Disturbance: A 500 kV line and the 500/230 kV transformer bank tripped on differential protection for a single-line-to-ground fault (3.5 cycle clearing).

August 25, 2021, Lytle Creek Disturbance: A fire burning in Lytle Creek caused a 500 kV line to trip.

- IBR generation loss:
- 765 MW (Victorville)
- 605 MW (Tumbleweed)
- 511 MW (Windhub)
- 583 MW (Lytle Creek)
- IBR generation loss caused by:
- Protection settings
- Lowest Frequency = 59.91 Hz (July 4)
- IBR models were **not** accurate



Figure 1.2: CAISO BPS-Connected Solar PV during Disturbance



Figure 1.11: System Frequency Response for Each Disturbance [Source: UTK/ORNL]



Recommendations

GOs

 Implement the recommendations contained in NERC reliability guidelines, technical reports, and white papers to mitigate known reliability issues related to BPS-connected solar PV resources (adopt the performance recommendations)

PCs and TPs

- Implement the recommendations contained in NERC reliability guidelines, technical reports, and white papers to mitigate known reliability issues
- Should have clear requirements to gather EMT models at the time of interconnection and execute EMT studies to ensure proper ridethrough performance for BPS fault events
- Ensure that modeling requirements include accurate representation of the causes of tripping from these four disturbances and all past disturbances analyzed by NERC
- Implement model checks that ensure the models match actual equipment during the interconnection process and during commercial operation







2022 – Panhandle Wind Disturbance

Event 1: A phase-to-phase fault occurred on a radial 345 kV generator tie line that connects a wind plant to the ERCOT system. The fault cleared normally.

Event 2: Another normally-cleared phase-tophase fault occurred on a 345 kV transmission circuit nearby.

- IBR generation loss = 765 MW (Event 1)
- IBR generation loss caused by:
 - Tie line tripping to clear the fault
 - Protection and control settings
- Lowest frequency = 59.90 Hz
- IBR models were **not** accurate







Figure I.6: System Frequency Response for First Fault Event



Recommendations

GOs

- High-resolution monitoring equipment at the plant POI and on collector feeders
- Plant SCADA data with 1–2 second resolution
- Plant-level controller measurements, set points, control settings, and other quantities
- Synchrophasor data at the POI
- Inverter-level fault codes
- Inverter-level oscillography data
- Time-synchronized measurements
- Sufficient retention
- Provide models that include any control or protection function that can trip the facility

PCs and TPs

- Perform detailed model quality review for all IBRs connected to the BPS
- Compare both positive sequence and EMT model performance with actual plant performance





2022 – Odessa Disturbance

On June 4, 2022, a surge arrestor failed at a synchronous generation facility in Odessa, Texas, causing a B-phase-to-ground fault on the 345 kV system. The fault cleared in three cycles.

- IBR generation loss: approximately 1700 MW
- IBR generation loss caused by:
 - Protection settings
 - Momentary cessation
- Lowest frequency = 59.7 Hz
- IBR models were **not** accurate



Figure I.4: ERCOT BPS-Connected Solar PV Generation during Disturbance [Source: ERCOT]



Figure I.5: ERCOT System Frequency



Recommendations

GOs

- Should mitigate any abnormal performance issues identified in the 2021 or 2022 Odessa disturbances and have evidence of accurate facility modeling when compared to actual facility performance and as-built control settings and parameters
- Should ensure that all studies performed for their facility include models that are as representative of the facility as possible
- Should ensure that the models and as-built settings match throughout the entire interconnection and commissioning process; any changes to planned equipment should be reported to the transmission entity immediately

PCs and TPs

- Perform detailed model quality reviews for all IBRs connected to the BPS
- Compare both positive sequence and EMT model performance with actual plant performance
- Create explicit and detailed requirements for product performance, model quality, and model validation and verification
- Should require GOs to provide verification reports that show that all parameters affecting facility performance and ride-through capability are captured in the model
- Should focus on obtaining positive sequence and EMT models verified by the equipment manufacturer and confirm that they contain accurate reflections of the controls, settings, and protections installed (or to be installed) on-site

Key Takeaway

The abnormal performance issues observed by all affected solar PV facilities should have been identified during the interconnection study process, during plant design, or during commissioning. The occurrence (and systemic recurrence) of performance issues demonstrates a failure of the interconnection studies, commissioning practices, and periodic plant performance review.

Key Takeaway

Inverter manufacturers highlighted that many of the modeling and study issues stem from a lack of clear modeling requirements. They also emphasized a disconnect during the commissioning process that likely leads to inaccurate models due to insufficient "true up" during commissioning and trial operation. Lastly, the manufacturers strongly advocated for the use of userdefined models (where necessary) since the standard library models often have deficiencies in accurately representing the inverter controls.

Key Takeaway

The majority of solar PV facilities involved in the 2021 Odessa Disturbance were also involved in the 2022 Odessa Disturbance. Some facilities made changes to mitigate the causes of reductions after the first event but subsequently tripped on other unexpected forms of protection in the second event.

Key Takeaway

Significant deficiencies exist for inverterbased resources both in positive sequence and EMT models. This includes the use of standard library models that cannot match actual inverter controls, incorrect parameterization of the models, insufficient model fidelity (i.e., missing protections or controls), and lack of model quality checks.

Key Takeaway

Model quality tests intended to check model accuracy are mixed with plant performance tests against interconnection requirements. This appears to incentive inaccurate models that pass performance criteria and disincentives model accuracy throughout the interconnection process.



2023 – Southwest Utah Disturbance

At 08:51 Pacific time, a single-lineto-ground fault occurred on a 345 kV transmission circuit in the Southern Nevada/Southwest Utah area. Protective relaying cleared the fault normally in 3.5 cycles.

- IBR generation loss: Approximately 900 MW
- IBR generation loss caused by:
 - Protection settings
 - Control settings
- Lowest frequency = 59.89 Hz
- IBR models were **not** accurate







Recommendations

GOs

- Should conduct an assessment of their facility's antiislanding settings and identify any potential performance issues that could arise from disabling these functions. Anti-islanding protection should generally not be used for BPS-connected inverterbased resources and should be coordinated with the interconnecting TO to determine appropriate setting
- Should work with OEMs to proactively implement corrective actions to eliminate the performance issues with their inverters

PCs and TPs

 Should implement modeling requirement enhancements as early as possible to gather highquality and accurate models for newly connecting facilities





2022 – California Battery Energy Storage System Disturbances

On March 9, 2022, a generator bus was faulted when a generator circuit breaker had an internal failure at a natural-gas-fired, simplecycle facility in Riverside County, California, causing a C-phase-toground fault on the 220 kV system. Generator units relayed, disconnecting the natural gas generators that were carrying 694 MW. The fault was cleared in approximately 4.5 cycles

On April 6, 2022, a B-phase-to-ground fault occurred on a 220 kV bus at a new BESS plant that was undergoing testing. The fault was cleared in approximately four cycles

- IBR generation loss:
- March: 408 MW (123 MW BESS)
- April: 498 MW
- Protection settings caused the IBR generation loss
- Lowest frequency = 59.92 Hz
- IBR models were **not** accurate





SALING WORKSHOP



Summary – Models Not Accurate



FERC Order 901 – Response to Disturbances

- At least 12 disturbance reports on the Bulk-Power System (BPS) show IBRs acting unexpectedly and adversely in response to normally cleared transmission line faults on the BPS, each highlighting one or more common mode failures of IBRs of various sizes and voltage connection levels
 - An average of approximately 1,000 MW of IBRs entering into momentary cessation or tripping in the aggregate
- Imperative for NERC to develop new or modified Reliability Standards as directed in this final rule to address reliability concerns related to IBRs at all stages of interconnection, planning, and operations
- FERC directed NERC to develop new or modified Reliability Standards addressing reliability gaps pertaining to IBRs in four areas:
 - Data sharing
 - Model validation
 - Planning and operational studies
 - Performance requirements



The Reliability Standards must require that Generator Owners, Transmission Owners, and Distribution Providers share validated modeling, planning, operations, and disturbance monitoring data for all IBRs with Planning Coordinators, Transmission Planners, Reliability Coordinators, Transmission Operators, and Balancing Authorities so that the latter group has the necessary data to predict the behavior IBRs and their impact on the reliable operation of the Bulk Power System

- Currently effective Reliability Standards do not ensure that BPS planners and operators receive disturbance monitoring data
 regarding all generation resources capable of having a material impact on the reliable operation of the BPS, including registered
 IBRs. Such data is needed to adequately assess disturbance events (e.g., a fault on the line) and the behavior of IBRs during those
 events. Without adequate monitoring capability, the disturbance analysis data for a system event is insufficient to effectively
 determine the causes of the system event
- Limitations on the availability of event data have hampered efforts by NERC, stakeholders, and industry to determine the causes of various events since 2016
- NERC has found that the existing disturbance monitoring equipment is not sufficient (e.g., lack of high-speed data captured at the IBR or plant level controller and low-resolution time stamping of inverter sequence of event recorder information) to analyze the widespread system events that have become more common since 2016



The Reliability Standards must require that all IBR models are comprehensive, validated, and updated in a timely manner, so that Planning Coordinators, Transmission Planners, Reliability Coordinators, Transmission Operators, and Balancing Authorities can adequately predict the behavior of IBRs and their impacts on the reliable operation of the BPS.

- Any generation resource model's performance must be verified by the Generator Owner using realworld data to confirm that the generation resource model adequately reflects actual, as-built settings, historic performance, and/or field-testing data
- Once the Generator Owners for registered IBRs, Transmission Owners for unregistered IBRs, and Distribution Providers for IBR-DERs in the aggregate verify plant models, BPS planners and operators must validate and update system models (i.e., planning and operation transmission area models as well as interconnection-wide models) by comparing the provided data and resulting system models against actual system operational behavior



FERC Order 901: IBR Planning and Operational Studies

The Reliability Standards must require that planning and operational studies include validated IBR models to assess the reliability impacts of IBRs on the reliable operation of the BPS. The Reliability Standards must require that planning and operational studies assess the impacts of all IBRs within and across planning and operational boundaries for normal operations and contingency event conditions.







FERC Order 901: IBR Performance Requirements

The Reliability Standards must ensure that registered IBRs will provide frequency and voltage support during frequency and voltage excursions in a manner necessary to contribute toward the overall system needs for essential reliability services The Reliability Standards must establish clear and reliable technical limits and capabilities for registered IBRs to ensure that all registered IBRs operate in a predictable and reliable manner during normal operations and contingency event conditions

The Reliability Standards must require that the operational aspects of registered IBRs contribute toward meeting the overall system needs for essential reliability services

The Reliability Standards must include post-disturbance ramp rates and phase lock loop synchronization requirements for registered IBRs NERC must submit new or modified Reliability Standards that establish IBR performance requirements, including requirements addressing frequency and voltage ride through, post-disturbance ramp rates, phase lock loop synchronization, and other known causes of IBR tripping or momentary cessation

New or modified Reliability Standards must require disturbance monitoring data sharing and post-event performance validation for registered IBR



ERCOT Actions to Address IBR Modeling Issues – Model Tests

Requirement	Applicable Facilities	Required Tests ⁽¹⁾	When to Update	Responsible Entity	Planning Guide Language
Model Quality Test for PSS/E, TSAT, and PSCAD Models (A single report should show the PSS/E, TSAT, and PSCAD model responses overlaid on the same plot axes.)	 All Resources and Inverter- Based Transmission Elements TSAT required if utilizing a user-defined model (UDM) PSCAD generally required for Inverter-based Resources (IBRs) and Inverter-based Dynamic Transmission Elements 	Flat start, small and large voltage disturbance, small frequency disturbance, and system strength tests (system strength test is only required for inverter-based devices) When running PSCAD MQT, also include: • Phase angle jump test	 A new or updated PSS/E, TSAT, or PSCAD model. Model updates are required: 1. When there is a change at the facility (refer to flow chart on previous page). 2. To enter QSA. 3. Before requesting Part 3 approval. 4. Within 30 days of Part 3 approval. 5. Completing MOD-026/027 studies. 	Facility owner (RE, IE, or TSP)	PG 6.2(5)(c), PG 6.2.1, PG 5.5(6)(b) PG 5.5(4), DWG Procedure Manual 3.1.5
Unit Model Validation for PSCAD Model ⁽²⁾	Inverter-based Resources (IBRs)	Step change in voltage, large voltage disturbance, system strength, phase angle jump, and subsynchronous tests	A new PSCAD model provided after 3/1/21. (UMV reports should not need updating for model parameter updates.)	Facility owner (RE or IE)	PG 6.2(5)(d), DWG Procedure Manual 3.1.6
Model Parameter Verification ("Verification Report")	All Resources and Inverter- Based Transmission Elements	Provide evidence that tunable model parameters match what is implemented in the field. Evidence can take the form of screenshots, nameplate photographs, signed manufacturer commissioning reports, etc.	 A report is required: Within 30 days of Part 3 approval, Within 12 to 24 months after Part 3 approval. (Projects built before March 1, 2021, required by March 1, 2023), A minimum of every ten years, and Within 30 days of implementing a change at the facility. 	Facility owner (RE, IE, or TSP)	PG 5.5(5) PG 5.5(6)(c), PG 6.2(5)(b)





89

New frequency and voltage ride-through requirements for IBRs in the ERCOT system have been approved to enhance grid reliability

The requirements aim to ensure that IBRs can remain connected to the grid during voltage sags and frequency disturbances, preventing cascading outages

The requirements mandate maximizing ride-through capabilities through software upgrades, hardware modifications, and parameterization adjustments, while also requiring specific reports and certifications to demonstrate compliance



IBRs play a crucial role in maintaining grid stability

Accurate IBR models are needed to ensure reliability (accurate models = accurate study results)

Existing and proposed requirements will help improve the accuracy of IBR models







Sli.do (#TXRE)

Slido Question

What kind of facility does your entity have?

- A. Category 1
- B. Category 2
- C. Both Category 1 and Category 2
- D. Not Applicable

Category 1 IBR GO/GOP

- Aggregate nameplate capacity >75 MVA connected at >100 kV
- BES IBRs

Category 2 IBR GO/GOP

- Aggregate nameplate capacity >20 MVA connected at >60 kV
- Non-BES IBRs 1









A plant/facility consisting of individual devices that are capable of exporting Real Power through a power electronic interface(s) such as an inverter or converter, and that are operated together as a single resource at a common point of interconnection to the electric system. Examples include, but are not limited to, plants/facilities with solar photovoltaic (PV), Type 3 and Type 4 wind, battery energy storage system (BESS), and fuel cell devices.



Enhanced Grid Reliability and Stability

- Predict and mitigate instabilities, ensuring grid stability
- NERC Reliability Standards the "MOD" family

Effective Performance Validation

• Validates IBR behavior during grid disturbances

Improved Planning and Operational Studies

- FERC Order No. 901
- Support IBR integration into the BPS





MOD-026-1 Overview

Purpose

 Verify that the generator excitation control system or plant volt/var control function model and the model parameters used in dynamic simulations accurately represent system behavior when assessing BES reliability

Applicability

- Generator Owner
- Transmission Planner



MOD-026-1 Flowchart



MOD-026-1 Internal Controls

Documentation and Record Keeping

- Formal documented process for verifying models and data
- Ensure responses are given/received within required timeline. Doing so will help ensure models are usable and timely
- Request recipients, confirm receipt, and acknowledge deadlines

Verification and Quality Assurance

- Internal reviews of model accuracy before submission
- Confirm software version and compatibility







MOD-032-1 Overview

Purpose

• Establish consistent modeling data requirements and reporting procedures for development of planning horizon cases necessary to support analysis of the reliability of the interconnected transmission system.

Applicability

- Balancing Authority
- Generator Owner
- Load Serving Entity
- Planning Authority and Planning Coordinator
- Resource Planner
- Transmission Owner
- Transmission Planner
- Transmission Service Provider





MOD-032-1 Flowchart



MOD-032-1 Internal Controls

Data Verification and Validation

 Implement processes to verify and validate modeling data accuracy

Defined Reporting Procedures

• Establish clear procedures for data submission and communication protocols with PCs and TPs

Documentation and Record Keeping

- Request recipients, confirm receipt, and acknowledge deadlines
- Ensure responses are received within required timeline
- Retain evidence, such as email records or postal receipts

100





MOD-033-2 Overview

Purpose

• To establish consistent validation requirements to facilitate the collection of accurate data and building of planning models to analyze the reliability of the interconnected transmission system

Applicability

- Planning Coordinator
- Reliability Coordinator
- Transmission Operator



MOD-033-2 Flowchart

Requirement 1: Each PC shall implement a documented data validation process that includes the attributes in subparts 1.1-1.4 of R1. Documentation Planning Coordinator (PC) Reliability Coordinator (RC) **Requirement 2:** Each RC and TO shall provide actual system behavior data (or a written response that it does not have the requested data) to any PC performing validation under R1 within 30 calendar days of written request. Transmission Operator (TO)

Shing workshop

102

Information to be Considered by CMEP Staff Regarding Inverter-Based Resources: ERO Enterprise CMEP Practice Guide NERC Projects related to FERC Order 901: Project 2020-06 Verifications of Models and Data for Generators Project 2022-02 Uniform Modeling Framework for IBR



103

Questions?





Texas RE Spring Standards, Security, & Reliability Workshop



AGENDA

- Welcome and Instructions
- Executive Welcome
- IBR Registration
- IBR Risk Elements
- IBR Modeling Challenges
- Preparing for Audits and Self-Reporting
- Low Impact BES Cyber Systems
 <u>Risk Elements</u>
- <u>Physical Security Emerging</u> <u>Risks and Considerations</u>
- High Frequency Conduct and Change Management
- NERC Standards Abeyance
 Process

Return at: 12:30 pm

To submit questions during the workshop, please visit **slido.com** and enter today's participant code: **TXRE**

	Ç Q&A	ı∣∣ Polls	
Type your question			6
			160
8 Your name (option	al)		Send



Preparing for Audits and Self-Report

Texas RE – Spring Workshop 4/23/2025

> **John Zerwas** Vice President, Regulatory

Eric Shaw NERC Compliance Manager

Basic Prerequisites

Formal Compliance Program

Subject Matter Experts

Baseline Current State of Program

Strong Internal Controls

Compliance Program

Establishes Framework

Creates Accountability

Fosters Engagement

Encourages Ethical Conduct Promotes Strong Culture of Compliance
Standards Owner Matrix

- Allocates Responsibilities for Each Applicable Standard and Requirement
 - Standard Owner
 - Requirement Owner
 - Program Sponsor / Stakeholder

Standard	Req. Standard		Requirement	Program Sponsor
Version	Number	Owner	Owner	Stakeholder
CIP-002-5.1a	R 1.	Director or Manager	Subject Matter Expert	VP or Director
CIP-002-5.1a	1.1.	Director or Manager	Subject Matter Expert	VP or Director
CIP-002-5.1a	1.2.	Director or Manager	Subject Matter Expert	VP or Director
CIP-002-5.1a	1.3.	Director or Manager	Subject Matter Expert	VP or Director
CIP-002-5.1a	R 2.	Director or Manager	Subject Matter Expert	VP or Director
CIP-002-5.1a	2.1.	Director or Manager	Subject Matter Expert	VP or Director
CIP-002-5.1a	2.2.	Director or Manager	Subject Matter Expert	VP or Director
	Standard Version CIP-002-5.1a CIP-002-5.1a	Standard Version Req. Number CIP-002-5.1a R1. CIP-002-5.1a 1.1. CIP-002-5.1a 1.2. CIP-002-5.1a 1.3. CIP-002-5.1a R2. CIP-002-5.1a 2.1. CIP-002-5.1a 2.2.	Standard VersionReq. NumberStandard OwnerCIP-002-5.1aR1.Director or ManagerCIP-002-5.1a1.1.Director or ManagerCIP-002-5.1a1.2.Director or ManagerCIP-002-5.1a1.3.Director or ManagerCIP-002-5.1a2.1.Director or ManagerCIP-002-5.1a2.1.Director or Manager	Standard VersionReq.StandardRequirementOurnerOwnerOwnerCIP-002-5.1aR1.Director or ManagerSubject Matter ExpertCIP-002-5.1a1.1.Director or ManagerSubject Matter ExpertCIP-002-5.1a1.2.Director or ManagerSubject Matter ExpertCIP-002-5.1a1.3.Director or ManagerSubject Matter ExpertCIP-002-5.1a2.1.Director or ManagerSubject Matter ExpertCIP-002-5.1a2.1.Director or ManagerSubject Matter ExpertCIP-002-5.1a2.1.Director or ManagerSubject Matter ExpertCIP-002-5.1a2.1.Director or ManagerSubject Matter ExpertCIP-002-5.1a2.2.Director or ManagerSubject Matter Expert

Developing a Baseline



- Deep Dive Review / Gap Analysis
- Internal Review by SMEs and Compliance Personnel
- Utilize Consultants
- Identify Opportunities for Continuous Improvement

Internal Controls





Preparing for Audit

270-Day Audit Notice Received



Approach Audit with Goodwill

Cooperative and Responsive

Organize/Package Responses

Openness and Transparency

Quickly Resolve any Issues

Audit

Rally the Team

- Communicate Details of the Audit Notice
- Ensure Full Support from all Levels of the Organization
 - Verify that everyone understands the assignment
 - Keep everyone informed throughout the process
- Establish Expectations
 - Emphasize the importance of meeting due dates
 - Ensure availability of team members
 - Scheduling around vacations and other absences



Audit

Develop a Clear Audit Strategy

• Schedule Key Dates

- Initial RSAW drafts
- Management/Legal reviews
- Final edits
- Final due dates
- Block calendars for known or anticipated audit dates



Quick Tip



CIP Evidence Tool

- Be familiar with the tool
- Know how to transfer data and populate fields
- Prepopulate and keep up-to-date if possible

Developing RSAWs

Drafting the Narrative

- Describe in Detail how the Entity Maintains Compliance
- Utilize Internal Policies, Processes, Procedures, Plans
- Narrative Should Answer:
 - "Auditors Notes" in the RSAW
 - "Engagement Common Questions" on Texas RE's Website



Packaging Evidence

Preparing Evidence for Submittal

- PDF
- Bookmark
- Annotate

Bookmark Settings

ocument Pro	operties					
Description	Security	Fonts	Initial View	Custom	Advanced	
Layout and	d Magnifica	ation				
Naviga	tion tab:	Bookma	arks Panel and	Page	\sim	
Page	e layout:	Default			\sim	
Magn	ification:	Default			\sim	
Open	to page:	1	of 10			
Window O	ptions					
Resize	e window t	o initial p	age			
Center	r window o	on screen				
Open	in Full Scre	en mode				
Show:	File Name	~				

Bookmarks

PRC-023-4_R1_Attachment-01_ _System_Protection_Philosophy_07-28-2020	x
UTILITIES	
SYSTEM PROTECTION PHILOSOPHY	
Prepared for: TRANSMISSION GROUP	

Bookmanks	
System Protection Philosophy	Û)
Bus Protection	
Instrument Transformers	
Zone Protection	

Packaging Evidence

Example of Annotations

Analog Channels

A# Phase		Analog Channel Description		Туре СТ	CT/PT	Full Scale	Chassis# If Virtual	
A1 Va	138kV	Line Ph A Pot	v(Vac)	1200.000	200.000	1-1		
A2	Vb	138kV	Line Ph B Pot	v(Vac)	1200.000	200.000	1-1	
A3	Vc	138kV	Line Ph C Pot	v(Vac)	1200.000	200.000	1-1	
A4	la	138kV	Line Ph A Curr	c(Aac)	240,000	100.000	1-2	-
A5	b	138kV	Line Ph B Curr	c(Aac)	240.000	100.000	1-2	
A6	lc	138kV	Line Ph C Curr	c(Aac)	240.000	100.000	1-2	
A7	In	138kV	Line Ph Neut Curr	c(Aac)	240.000	100.000	1-3	
A8	Va	138kV	Line Ph A Pot	v(Vac)	1200,000	200,000	1-3	and
A9	Vb	138kV	Line Ph B Pot	v(Vac)	1200.000	200.000	1-3	and
A10	Vc	138kV	Line Ph C Pot	v(Vac)	1200.000	200,000	1-4	oltage and Current
A11	а	138kV	Line Ph A Curr	c(Aac)	300.000	100.000	1-4 🤇	configuration for
A12	b	138kV	Line Ph B Curr	c(Aac)	300,000	100,000	1-4 r	neasurements on
A13	c	138kV	Line Ph C Curr	c(Aac)	300.000	100.000	1-5 t	he low side of the
A14	In	138kV	Line Ph Neut Curr	c(Aac)	300,000	100,000	1-5	
A15	Va	138 kV	Line Ph A Pot	v(Vac)	1200.000	200.000	1-5	
A16	Vb	138 kV	Line Ph B Pot	v(Vac)	1200.000	200,000	1-6	



Preparing a Self-Report

Self-Report

Initiate Investigation

Contact Texas RE For Guidance

- Confirm non-compliance
- Identify potential solutions to end non-compliance

- Enforcement Attorney
- Self-Log or Self-Report

Self-Report



- Gather all available information/data
- Drill past the symptoms
- Address the root cause

- Focus on ending non-compliance
- Short-term and long-term mitigation activities

- Reinforce existing Internal Controls
- Develop new Internal Controls

Maintain Communication

Have Questions or Need Clarification?

• Act Quicky

- Audit reach out to lead auditor
- Self-Report reach out to enforcement attorney
- Schedule meetings or interviews

Key Takeaways From Audit or Self-Report

- Opportunities for Continuous Improvement
- Lessons Learned
- Implement Recommendations from Auditors
- SME Gain Knowledge & Experience
- Strengthened Compliance Program









Low Impact BES Cyber System Risk Elements: Remote Connectivity, Physical Security, and Incident Response

Devin Ferris Manager, CIP Compliance Monitoring



2025 CMEP IP

2024

Remote Connectivity

Supply Chain

Physical Security

Incident Response

Stability Studies

Inverter-Based Resources

Facility Ratings

Extreme Weather Response

2025

Remote Connectivity

Supply Chain

Physical Security

Incident Response

Transmission Planning and Modeling

Inverter-Based Resources

Facility Ratings

Extreme Weather Response



CIP-003-8 – Security Management Controls

R1. Each Responsible Entity shall review and obtain CIP Senior Manager approval at least once every 15 calendar months for one or more documented cyber security policies that collectively address the following topics: [Violation Risk Factor: Medium] [Time Horizon: Operations Planning] 1.1. For its high impact and medium impact BES Cyber Systems, if any: 1.1.1. Personnel and training (CIP-004); 1.1.2. Electronic Security Perimeters (CIP-005) including Interactive Remote Access; Physical security of BES Cyber Systems (CIP-006); 1.1.4. System security management (CIP-007); **CIP-003-8** 1.1.5. Incident reporting and response planning (CIP-008); 1.1.6. Recovery plans for BES Cyber Systems (CIP-009); 1.1.7. Configuration change management and vulnerability assessments (CIP 010); 1.1.8. Information protection (CIP-011); and 1.1.9. Declaring and responding to CIP Exceptional Circumstances. For its assets identified in CIP-002 containing low impact BES Cyber Systems, if 1.2. any: 1.2.1. Cyber security awareness; 1.2.2. Physical security controls; 1.2.3. Electronic access controls;

R2. Each Responsible Entity with at least one asset identified in CIP-002 containing low impact BES Cyber Systems shall implement one or more documented cyber security plan(s) for its low impact BES Cyber Systems that include the sections in Attachment 1.





Risk Element – Remote Connectivity





Low Impact BES Cyber System Risk Elements

Third-Party Monitoring and Control





This Photo by Unknown Author is licensed under CC BY-NC-ND

Phishing and Social Engineering

Supply Chain Compromise

Human Error

Credential Harvesting

Escalation of Privilege

Malware

Ransomware

Unauthorized Access

Lack of Visibility and Control

Expanded Attack Surface

Data Loss



Best Practices & Internal Controls

Least Privilege	Network Segmentation	Zero Trust
Endpoint Protection	Encryption	Intrusion Detection System (IDS)
Multi-Factor Authentication (MFA)	Privileged Access Management (PAM)	Patch Management
Change Control	Password Management and Enforcement	Identity and Access Management



This Photo by Unknown Author is licensed under <u>CC BY-SA-NC</u>



Risk Element – Physical Security



Control physical access, based on need as determined by the Responsible Entity, to:



1) the asset or the locations of the low impact BES Cyber Systems within the asset, and



2) the Cyber Asset(s) providing electronic access controls implemented for Section 3.1, if any









Risk Element – Incident Response



Identify, Classify, and Respond



Determination of Reportable Cyber Security Incident and Notification



Testing & Maintenance



Low Impact BES Cyber System Risk Elements







Low Impact BES Cyber System Risk Elements







Low Impact BES Cyber System Risk Elements

Vendor Electronic Remote Access Security Controls

April 1, 2026





Low Impact BES Cyber System Risk Elements

Section 6 – Vendor Electronic Remote Access Security Controls

3.1 - Electronic Access Controls



Routable Protocol: Entering <u>or</u> Leaving Section 6. <u>Vendor Electronic Remote Access Security Controls</u>: For assets containing low impact BES Cyber System(s) identified pursuant to CIP-002, that allow vendor electronic remote access, the Responsible Entity shall implement a process to mitigate risks associated with vendor electronic remote access, where such access has been established under <u>Section 3.1</u>. These processes shall include:

- 6.1 One or more method(s) for determining vendor electronic remote access;
- 6.2 One or more method(s) for disabling vendor electronic remote access; and
- **6.3** One or more method(s) for detecting known or suspected inbound and outbound malicious communications for vendor electronic remote access.



Questions?




Texas RE Spring Standards, Security, & Reliability Workshop



AGENDA

- Welcome and Instructions
- Executive Welcome
- IBR Registration
- IBR Risk Elements
- IBR Modeling Challenges
- Preparing for Audits and Self-Reporting
- Low Impact BES Cyber Systems
 <u>Risk Elements</u>
- <u>Physical Security Emerging</u> <u>Risks and Considerations</u>
- High Frequency Conduct and Change Management
- NERC Standards Abeyance
 Process

Return at: 1:45 pm

To submit questions during the workshop, please visit **slido.com** and enter today's participant code: **TXRE**

	© Q&A	ı∣∣ Polls	
Type your question			6
			160
8 Your name (option	nal)		Send



Physical Security: Emerging Risks and Considerations

Texas RE - Spring Standards, Security, and Reliability Workshop April 23, 2025

Sofia Weir, E-ISAC Senior Physical Security Analyst

TLP:AMBER // FOUO

RELIABILITY | RESILIENCE | SECURITY







TLP: Amber

Limited disclosure, restricted to participants' organization and its clients (see Terminology Definitions).

RELIABILITY | RESILIENCE | SECURITY



- Existing/static risks to sector
- Emerging Risks
 - New Assets Affected by Operational Disruptions
 - Increasingly Impactful Persistent Threats
 - Supply Chain Challenges Converge with Geopolitics
 - Disruptive Action Following Public Discontent
- Final Considerations for AOOs and Planners
- Q&A

Agenda





149 TLP:AMBER // FOUO

RELIABILITY | RESILIENCE | SECURITY





Extremists advocating for sabotage against the grid



Insider threat

Operational impacts to generation, transmission, or distribution of electricity

Monetary impacts related to theft of O copper, tools, vehicles, and more





Workplace violence, risk to organization and personnel, especially field workers



New Assets Affected by Operational Disruptions





Considerations - New Assets Affected by Operational Disruptions

Considerations	For AOOs	For the State
Could your assets be affected?	Owners of wind and solar sites or other assets with operational dependencies on communication infrastructure	EIA: In 2023, Texas wind accounted for 28% of all U.S. wind-sourced electricity.
Are your critical facilities vulnerable to operational disruptions?	Are redundant communications in place? Is wind/solar operational critical?	EIA: TX industrial sector, accounts for more than half of the state's energy consumption and for 24% of the nation's total industrial sector energy use.
Are you already tracking these types of tactics within your fleet?	Develop or borrow physical security incident tracking methodology.	Encourage entities in Texas to track and share incidents.

#1: New TTPs



#2: Impactful Thefts or Attempts







#2: Impactful Thefts or Attempts

Considerations	For AOOs	For the State
What are your unacceptable consequences related to theft?	Loss of industrial load? Loss of ### customers? Loss of \$\$\$ worth of copper? Safety impacts of ungrounded equipment?	Support discussion.
Impact-chain of criminal environment and copper markets on operations.	High copper prices have strong bearing on thefts of copper.	Coordination between utilities, comms providers, copper recyclers, law enforcement, fusion center, state enhances response effectiveness.
Information sharing and benchmarking.	Share incidents with E-ISAC at <u>operations@eisac.com</u> or 202-790-6000 (24/7).	Encourage benchmarking – requires a mature incident tracking program.



Supply Chain Challenges Converge with Geopolitics

#3: Supply Geopolitics







#3: Supply Geopolitics



Considerations	For AOOs	For the State
Critical supply chain inputs.	Analyze supply chain inputs for each asset type in fleet.	Enhance conversation by providing guidance on expected growth needs.
Geopolitical factors and their influence on supply chain inputs.	What regions face a concentration of risk?	What were the lessons learned from the pandemic supply chain shock? How can these be leveraged to increase resilience to future geopolitically-themed shocks?
Other complexities.	What other complexities might your org face related to supply chain and geopolitical constraints?	How can the state help inform owners on this front for long time horizon issues?

DOE: "Many critical components supporting the power grid have limited to no domestic manufacturing capacity and face complex challenges in supporting a rapid expansion of the grid to meet multiple objectives, including decarbonization goals."



#4: Flashpoints

	Examples	
COVID-19 pandemic and 5G conspiracy	New extremist publications	Israel-Palestine Conflict
Tesla and Elon Musk	Unrest in the PNW	Dissatisfaction with new pipeline construction
Major U.S. Elections	U.S./Canada Tariffs	Ukraine-Russia War

RELIABILITY | RESILIENCE | SECURITY



#4: Flashpoints



Considerations	For AOOs	For the State
Determining potential flashpoint events.	What types of assets in your fleets are most at risk from a public discontent perspective? Are there any events that could serve as inflection points?	How can state messaging support security and safety of grid assets?
Indicators	Monitor these closely and programmatically.	Continue to support coordination with law enforcement and intelligence partners by advocating for our sector.
Mitigations	Build flexibility into security posture, shields up when needed to minimize exposure.	Discuss unacceptable consequences for critical infrastructure from the state perspective with respect to public discontent and disruptive action.



Final Considerations for AOOs and Planners

Planners		AOOs		
Guide and	Monitor the	Mitigate	Leverage	Maintain
enable	medium to	ongoing	partners to	awareness
sensible	long term	predictable	support	of longer-
solutions	horizon	risks	prioritization	term horizon

RELIABILITY | RESILIENCE | SECURITY



E-ISAC VISA Workshops

E-ISAC VISA Workshops

A framework for utilities to make informed risk-based and cost-effective decisions



VISA Workshop Benefits

- Cost-effective methodology
- Relies on subject matter expert input to determine overall system effectiveness
- Adaptable to all types of utilities, ideal for small/medium entities with limited resources
- Promotes developing sound business case to make informed risk-based decisions
- Provides confidence that a threat can be mitigated
- Helps utilities produce a portfolio of scenarios to justify upgrades

2025 Efforts

- 7 E-ISAC workshops...no cost
- 1. SnoPud (Snohomish, WA): April
- 2. ConEd (New York): July
- 3. EPCOR (Alberta, CA): Q2-Q3 TBD
- 4. Excel (Minnesota): Q2-Q3
- 5. Littleton & NEPPA (Boston, MA): Sept
- 6. HydroOne (Toronto, CA): Nov
- 7. Pending (NPCC): Q3-Q4

More workshops available at direct cost

What's next

- Grow VISA into a regional based program
- Tailored for small/medium utilities with limited budgetary resources







What physical security risk keeps you up at night?







Questions and Answers



RELIABILITY | RESILIENCE | SECURIT



High Frequency Conduct and Change Management

Katie Van Zee Director, Enforcement and Registration Roadmap

The CMEP IP and High Frequency Conduct

Root Cause and Change Management

Reliability Standards and Best Practices for Internal Controls







2025 CMEP Implementation Plan







High Frequency Conduct and Change Management

High Frequency Conduct

FAC-008 R6

 Facility Ratings must be updated for new or modified Facilities

PRC-005-6 R3

 Time-based maintenance program(s) for Protection System(s), Automatic Reclosing, and Sudden Pressure Relaying Components

CIP-004-7 R4 & R5

- Access management programs that require periodic verification of authorization
- Revocation of access upon employee termination or transfer

CIP-010-4 R1

- Baselining documentation needs to reflect current configurations for BES Cyber System and associated EACMS, PACS, and PCAs
- Changes must be tracked, authorized, verified, and tested if possible



Enforcement Tracking



Top Violations Discovered by NERC Standards in 2024



High Frequency Conduct and Change Management

Refresher on Root Cause





High Frequency Conduct and Change Management

The Importance of Root Cause

Essential to Prevention of Reoccurrence

• Mitigation activities must address the Root Cause





High Frequency Conduct and Change Management

Change Management and High Frequency Conduct



Stating workshop

High Frequency Conduct and Change Management

R1: Facility Ratings Methodology

R6: Facility Ratings consistent with methodology and must correctly identify Most Limiting Series Element (MLSE)

R8: Providing correct and current Facility Ratings to RC, PC, TP, TO, and TOP





Sampled FAC-008-5 R6 Noncompliance



High Frequency Conduct and Change Management

Root Cause Analysis

Failure to Update Facility Ratings Post Equipment Replacement/Upgrade

• Why?

Field Change Different from Design

• Why?

Omitted Equipment

• Why?



FAC-008-5 R6 Effective Change Management Procedures

A requirement for data entry verification

A clearly outlined approval process prior to changes

Notification to update inventory after a change

Confirmation that a change is implemented as planned

Checklist to verify Facility Ratings following a change

Validation through periodic reviews

A change process flowchart





Don't limit change management process to planned work

Include changes that occur during emergency repairs

Include changes following post storm or extreme weather restoration

Do include planned projects

Do include acquired facilities





Maintenance must be performed as described in the tables within the Standard

In accordance with:

- Minimum maintenance activities (what and how)
- Maximum maintenance intervals (how often)

Maintenance intervals depend on component attributes

- 4 Calendar Months
- 18 Calendar Months
- 6 Calendar Years
- 12 Calendar Years



Sampled PRC-005-6 R3 Noncompliance



Root Cause Analysis

Incomplete inventory after ownership/management transition

• Why?

Inventory records unorganized

• Why?

New/upgraded equipment not added to inventory

• Why?



Ineffective Change Management Procedures



PRC-005-6 R3 Effective Change Management Procedures

PSMP with master inventory	Periodic review of procedure and checklists	Training	A clearly outlined approval process prior to changes
Notification to update inventory after a change	Confirmation that a change is implemented as planned	A change process flowchart	Validation of inventory through periodic reviews



High Frequency Conduct and Change Management
Incorporate oversight into processes

• Secondary review of compliance task

Periodic review of completed PRC-005 paperwork to identify "lessons learned" to inform training

Verification of inventory for acquired Facilities



CIP-004-7



Sampled CIP-004-7 R4 Noncompliance and Root Cause



High Frequency Conduct and Change Management

Track CIP access requests

Additional verification steps in process

- Management oversight
- Peer review
- Analysis of linked or shared accounts

A clearly outlined approval process prior to changes

Confirmation that a change is implemented as planned

A change process flowchart





Additional verification steps in process

- Management oversight
- Peer review
- Analysis of shared accounts

Periodic access reviews











Sampled CIP-010-4 R1 Noncompliance and Root Cause



High Frequency Conduct and Change Management



A clearly outlined approval process prior to changes Confirmation that a change is implemented as planned





High Frequency Conduct and Change Management

Additional verification steps in process

- Management Oversight
- Peer Review

Verification of inventory

Periodic Sampling



Questions?





NORTH AMERICAN ELECTRIC RELIABILITY CORPORATION

NERC Supplemental Filing:

Abeyance

Lonnie Ratliff, Director of Compliance Assurance and Certification Texas RE Spring Standards, Security, and Reliability Workshop April 23, 2025

RELIABILITY | RESILIENCE | SECURITY



Supplemental Filing: Abeyance

What is the initial criteria for abeyance consideration?

- A high priority project given risks being addressed
- A new Reliability Standard or a modified Reliability Standard undergoing significant revisions
- It involves one or more of the following attributes:
 - new technology likely will be needed to implement the Reliability Standard;
 - new, emerging reliability issue with no consensus on specific best practices or
 - a high level of technical complexity

Example of current usage:

- Project 2024-03 Revisions to EOP-012-3 (Cold Weather) *
 - "From the effective date of Reliability Standard EOP-012-3 until October 1, 2027, the Compliance Enforcement Authority will
 not pursue an action under Sections 4A.0 or 5.0 of Appendix 4C to the Rules of Procedure for a failure to comply with
 Reliability Standard EOP-012-3 Requirement R1 Part 1.1 with respect to the calculation of the Extreme Cold Weather
 Temperature for an applicable generating unit, or any other failure to comply resulting from an incorrect calculation of the
 Extreme Cold Weather Temperature for that generating unit, against any entity acting in good faith to comply with the
 standard in accordance with the relevant implementation plan."

https://www.nerc.com/pa/Stand/Pages/Project-2024-03-Revisions-to-EOP-012-2.aspx



Supplemental Filing: Abeyance

What is the value of abeyance?	 To enhance NERC standards development process agility that the ERO Enterprise and industry have focused on the past few years Help reduce the concern over compliance risk during standards development so that the focus can be on addressing risks to reliability
When is abeyance considered?	 During the Standards Drafting process
What is the purpose of abeyance?	• Develop insights from initial implementation of the standard that can then be fed back to NERC and industry to further refine standards as needed
Who determines which Standards/Requirements/Parts for abeyance consideration?	 The ERO Enterprise will consider the candidates for the abeyance period

RELIABILITY | RESILIENCE | SECURITY



Abeyance – What it is NOT

Abeyance is NOT

- A free pass
- An extension of the implementation plan
- Time to sit and *wait* for feedback

What should you be doing?

- Working with your Region
- Talking with your peers



Abeyance: Common Questions

~	
~	-1
1	
<u> </u>	-

Will all Standards / Requirements have an abeyance period?



Where will the abeyance language be within the Standard?



What if I'm not audited during the abeyance period?



What current Standards or Projects have been flagged for abeyance?



Will the supplemental filing impact the self-logging process?

Abeyance: Common Questions, cont.



How does the information feed back to Standards for possible enhancements?

How will industry receive updates during the abeyance period?

Can a SAR be introduced during the abeyance period?

What is "good faith"?





Questions and Answers





Wrap-Up



Thank you for coming!

You will receive a short survey via e-mail. Please complete it to help Texas RE develop future outreach.

